



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

Partners in Learning at Northfield
408 New Road
Northfield, NJ 08225

www.sjwatertest.com
NJ DEP Certified Lab # 08006

Sample Location: Field Reagent

Date Sampled: 12/18/24

Time Sampled: 07:05

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W144919					
Lead	23-DEC-2024 13:37	<2.00	ug/L	2.0	15.5	SM3113B
Copper	23-DEC-2024 13:17	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Front Bathroom Sink

Date Sampled: 12/18/24

Time Sampled: 07:10

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W144920					
Lead	23-DEC-2024 13:44	<2.00	ug/L	2.0	15.5	SM3113B
Copper	23-DEC-2024 13:18	0.309	mg/L	0.05	1.3	SM3111B

Sample Location: Classroom Sink

Date Sampled: 12/18/24

Time Sampled: 07:12

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W144921					
Lead	23-DEC-2024 13:50	2.15	ug/L	2.0	15.5	SM3113B
Copper	23-DEC-2024 13:18	0.399	mg/L	0.05	1.3	SM3111B

Sample Location: Back Office Sink

Date Sampled: 12/18/24

Time Sampled: 07:14

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W144922					
Lead	23-DEC-2024 13:57	<2.00	ug/L	2.0	15.5	SM3113B
Copper	23-DEC-2024 13:18	0.067	mg/L	0.05	1.3	SM3111B

Sample Location: Back Student Bathroom Sink

Date Sampled: 12/18/24

Time Sampled: 07:16

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
Sample ID:	W144923					
Lead	23-DEC-2024 14:17	<2.00	ug/L	2.0	15.5	SM3113B
Copper	23-DEC-2024 13:19	0.216	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

12/24/2024

Date

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Partners in Learning at Northfield
Contact: Maryssa Siazon
Address: 408 New Road
 Northfield, NJ 08225
Phone:
Fax:

Lab ID#	Sample Location	Collection Date	Time	Matrix	Comp	No. of Bottles	Pres.	Analysis Requested	Comments
W14491	Field Reagent Blank	12/18/24	7:05	D	X	1 x 250	HNO3*	First Draw Lead and Copper	
W14492	Front bathroom sink	12/18/24	7:10AM	D	X	1 x 250	HNO3*	First Draw Lead and Copper	
W14493	Classroom sink	12/18/24	7:12 AM	D	X	1 x 250	HNO3*	First Draw Lead and Copper	
W14494	Back office sink	12/18/24	7:14 AM	D	X	1 x 250	HNO3*	First Draw Lead and Copper	
W14495	Back student bathroom sink	12/18/24	7:16 AM	D	X	1 x 250	HNO3*	First Draw Lead and Copper	
				D	X	1 x 250	HNO3*	First Draw Lead and Copper	
				D	X	1 x 250	HNO3*	First Draw Lead and Copper	
				D	X	1 x 250	HNO3*	First Draw Lead and Copper	
				D	X	1 x 250	HNO3*	First Draw Lead and Copper	
				D	X	1 x 250	HNO3*	First Draw Lead and Copper	
				D	X	1 x 250	HNO3*	First Draw Lead and Copper	

MATRIX ABBREVIATIONS: DIDRINKING WATER AAQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWSURFACE WATER WWWASTE WATER

Turnaround Time ___ SJWT Standard is 10-20 work days ___ Rush turnaround available upon request and lab approval ___	Report Format ___ Standard ___ NJ DEP Reduced Deliverables ___ NJ DEP Full Deliverables ___ Electronic Data Deliverables ___ PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp ___ °C	
			Yes No	

Sampled by: (Print) <u>Maryssa Siazon</u>	Received by: (Signature) <u>[Signature]</u>	Date 12/18/24	Time 9:12 AM
Relinquished by: (Signature) <u>[Signature]</u>	Received by: (Signature) <u>[Signature]</u>	Date 12/19/24	Time 1:00
Relinquished by: (Signature)	Received by: (Signature)	Date	Time